

To

The Principal,
The D.C Model School,
Babyal Road, Ambala Cantt.


Memo No. 513 Dated: - 11-8-2021

Subject: - Issuing of Building Structure Safety Certificate.

The School Building of D.C Model Sr. Sec. School, Kismat Nagar, Babyal Road, Ambala Cantt has been inspected by the undersigned alongwith JE concerned and it was found that building is structural safe for running school. The School building Safety Certificate is hereby given for the year 2021-2022 with the following Conditions:-

1. Water should not be allowed to stagnate around and on the roof of the Building.
2. If building is found cracked at any time, the same should be got vacated and repaired immediately.
3. Institution will be responsible for safety of building from every angle and firefighting equipment should be in functional condition.
4. If the building of this school is to be extended, the same should be first got approved from structural Engineer.
5. Proof checked structural drawings should be submitted to this office for record within 1 month after issuing the NOC.
6. Institute shall also ensure safety precautions from false ceiling and vitrified tiles used in dado.
7. NOC may be considered as cancelled by this office if the school violates any of the above points.

DA/NIL



Sub Divisional Engineer,
Provincial Sub Division No.6,
PWD B&R Br; Ambala Cantt.

Endst. No.

Dated

Copy forwarded to Executive Engineer, Provincial Division No.1, PWD B&R Branch, Ambala Cantt for information. w.r.t. office order vide memo no 7640 at 11/08/2021.

DA/NIL


Sub Divisional Engineer,
Provincial Sub Division No.6,
PWD B&R Br; Ambala Cantt.